

- Solar panel or DC power supply recharges 6 "AA" re-chargable Nickel Metal Hydride Batteries
- Can be programmed for automatic variable reserve, based on water usage history for high efficiency
- Solid state microprocessor with easy access front panel settings
- Service flow rate of 34 gpm, backwash 32 gpm
- Front panel display for time of day, days until next regeneration, volume remaining, current flow rate and total volume used (Totalizer)
- Four methods to initiate regeneration; meter immediate, meter delayed, time clock delayed or pressure differential
- Optional double backwash feature offers optimum regeneration, cleaning ability and efficiency
- Fully adjustable cycle times with 6-cycle control delivers controlled backwash, downflow brining/slow rinse, second backwash, fast rinse, refill and downflow service
- Coin Cell Lithium battery back-up with 8 hour carry over of time of day
- Backwash and brining ability to 21" diameter tanks
- Downflow regeneration/Upflow regeneration
- Level VI 15-volt output DC power supply provides safe and easy installation
- Patented one piece expanding seal spacer stack assembly
- Patented linearly reciprocating piston operation
- Control valve design provides optimum service and backwash rates
- Post treated water regenerant refill
- Reliable and proven DC drive

Water Specialist 1.25" SD/SP Control Specifications

	<u> </u>
Inlet/Outlet Fittings	3/4" to 1.5" NPS
Cycles	
Valve Material	•
Regeneration	
1.09010144011	
FLOW RATES	
Service @15 psi drop (includes meter, bypass, and 1.25" f	fitting kit)34 gpm
Backwash @ 25 psi drop (includes bypass)	
Cv Service	8.8
Cv Backwash	6.4
ODEDATING DESCRIPES	
OPERATING PRESSURES	00 noi 105 noi
Minimum/Maximum	20 psi – 125 psi
OPERATING TEMPERATURES	
Minimum/Maximum	40° – 110° F
METER	
Accuracy	± 5%
Flow Rate Range	0.25 – 34 gpm
Gallon Range	20 – 1,500,000 gallons
Totalizer	1000 - 9,999,000 gallons
DIMENSIONS & WEIGHT	4 00 II 0 D D (4 II N D 0)
Distributor Pilot	,
Drain Line	
Brine Line	•
Mounting Base	
Height From Top Of Tank	
Weight	4.5 lbs.
BATTERY SPECIFICATIONS - 2 OPTIONS FOR OPERATION	
6 AA nickel metal hydride batteries rechargeable for SP m	nodel
6 "D" cell alkaline batteries (disposable when discharge	
o B con anamie batteries (disposable when disonal ge	say for ob moder b batteries not moladed
CHARGING SPECIFICATIONS FOR SP MODEL- 2 OPTIONS F	OR OPERATION
Amorphous silicon solar panels capable of three tilt angle	es es
DC power supply with 15VDC output 500mA	
TANK APPLICATIONS	
Water Softener	
Water Filter (2)	6" – 24" diameter
CYCLES OF OPERATION	
OTOLES OF OF EMAILOR	Softener Filter
Cycle	Range of time in minutes
1. Backwash 1st (upflow)	•
Regenerate Draw/Slow Rinse (downflow or upflow)	
3. Backwash 2 nd (upflow)	
4. Fast Rinse (downflow)	
5. Regenerant Refill (in service with treated water)	
6. Service (downflow)	311 0010
o. Ooi vioo (downinow)	

When replacing batteries follow state or local regulations for recycling and disposal. Options: Backwash Filter, Bypass, Weather Cover

Compatible with the following typical concentration of regenerants or chemicals: Sodium chloride, potassium chloride, potassium permanganate, sodium bisulfite, chlorine and chloramines

- 1. Acquired by use of external drain line flow control
- 2. Filter tank size calculated @ 10 gpm of backwash per square foot of bed area